

Chen

11 September 1970

MEMORANDUM FOR: Acting Chief, Support Services Staff

SUBJECT : Proposed Changes in [REDACTED] Specifications

25X1A6d

1. Attached are the comments I have received from Mr. [REDACTED] concerning the Specifications from the [REDACTED] Engineers on the [REDACTED] I agree with him and believe these notes should be passed on to the Office of Logistics, Real Estate and Construction Division to be added to their corrections and changes.

25X1A9a

25X1A6a

2. In my review I found that the Specifications were not consistent as to the length of the file range. (Page VIII, Item 20.1, states " . . . consist of a 35-foot range . . . ") while discussions with Mr. [REDACTED] indicated they could be broken into two sections. Then again on Page 14-A-2 Item 3.1 states the shelving is 35 ft. long in ten 3 1/2 foot sections 10 ft. high. However, such a matter is an engineering item on which we need not comment.

25X1C4a

25X1A9a

3. I checked with [REDACTED] on the "Special Provision Section 1A" Time Schedules in Items 1.2.1 thru 1.3. He said he provided the time table to the Engineers and feels he can live within it if he gets the seven contract employees he is authorized. So far he has one on board in the [REDACTED] Maintenance Force and one more in process.

25X1A6a

4. On Page 14-A-3, Item 10, deals with safety devices. It does not use the word automatic, which [REDACTED] prefers, but the description seems to indicate they will be automatic and we need not comment unless you are thus inclined.

25X1A9a

5. In the floor plan Mr. [REDACTED] found a large section without the raised concrete flooring. Although it must have been the designers preference, [REDACTED] feels the plan will have an adverse effect on operations. He feels there will be too much up and down the ramp activity with the fork lift truck and he intends to speak to the engineers about having that floor area filled in with raised concrete as originally requested. I believe we can support him on this without disrupting the time schedules.

25X1A9a

25X1A9a

25X1A9a

Chief, Records Administration Branch

Attachment:

25X1A9a

As Approved For Release 2001/08/08 : CIA-RDP74-00005R000100120003-8

also specify floor plan